



COUNTY GOVERNMENT OF NYERI
OFFICE OF THE CHIEF OFFICER
DEPARTMENT OF TRANSPORT, PUBLIC WORKS, INFRASTRUCTURE & ENERGY

WHEN REPLYING PLEASE QUOTE OUR
REFERENCE NO AND DATE.

P.O. BOX 1112-10100

NYERI

Telephone 061 2030700

Email: infrastructure@nyeri.go.ke

13TH November, 2019

REF: NG-CDF/HM/SECURITY/VOL. 1 (04)

THE FUND MANAGER,
MUKURWEINI CONSTITUENCY,
P.O.Box 8-10103

NYERI

Dear Sir,

RE: **INSTALLATION OF SECURITY HIGH MAST FLOOD LIGHTS**

Reference is made to your letter dated 30TH October 2019 to the CEC Department of Transport, Public Works, Infrastructure and Energy by the Hon M.P. Mukurwei-ini Constituency on the above subject

We have no objection to installation of the Security High Mast flood lights in the aforementioned areas below and will endeavor to maintain them and pay the relevant electricity bills.

Proposed Areas


S/No	Project Title/site	Sub -location
1.	Wamachatha	Karidi
2.	Gatiki	Ichamara
3.	Pall Hill (Bohero)	Ngamwa
4.	Kibutio	Kibutio

However, we must approve the designs to conform to the latest lighting technology. The lanterns must be LED to save on the Energy Bills.

Our energy directorate should also oversee the installation to ensure conformity with engineering norms in the field.

And should there arise a need to relocate the High Mast Flood light for one reason or another we shall consult and agree on the way forward.

Yours Faithfully,


OS J.K.RINGERA
CHIEF OFFICER
TRANSPORT, PUBLIC WORKS, INFRASTRUCTURE & ENERGY

C.C

1. C.E.M- Transport, Public Works, Infrastructure & Energy

2. County Secretary/Head of Public Service

County Government

Nyeri